

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF KINGSTON-TERRILL)	
WATER DISTRICT FOR A DEVIATION PURSUANT)	CASE NO.
TO 807 KAR 5:066, SECTION 4(4),)	92-479
REGARDING WATER STORAGE)	

O R D E R

On November 10, 1992, Kingston-Terrill Water District ("Kingston-Terrill") filed a letter for a deviation from Commission Regulation 807 KAR 5:066, Section 4(4), which requires that each utility shall maintain water storage to ensure a minimum of one day's supply of its average daily water usage.

Kingston-Terrill also filed a letter from its supplier, Richmond Water, Gas and Sewerage Works ("Richmond Water"), which indicated and assured that it would provide Kingston-Terrill's needed storage for the next few years.


The Commission, having reviewed the application and information submitted subsequent thereto, and being otherwise sufficiently advised, finds that:

1. Kingston-Terrill has 100,000 gallons water storage capacity in its water distribution system.
2. Kingston-Terrill's average daily water usage is approximately 450,000 gallons per day.
3. Richmond Water is willing to provide Kingston-Terrill with needed storage capacity for the next few years.


IT IS THEREFORE ORDERED that Kingston-Terrill be and it hereby is granted a deviation from the water storage requirement of 807 KAR 5:066, Section 4(4), for so long as its agreement with Richmond Water remains in effect, but no later than January 1, 1996.

Done at Frankfort, Kentucky, this 7th day of December, 1992.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:


Executive Director